

POTW: New Kensington

DATE: 11/19/04

Local Limits Review Checklist				
	Y	N	N/A	Comment
1. Reevaluation conducted in accordance with sampling plan?				
• All pollutants included?	X			
• Data collection				
- Correct number of samples collected?	X			
- Correct sample locations?	X			
- Correct detection levels?	X			
2. POTW calculations correct?	X			
3. POTW data inputs correct?		X		Some revisions to inhibition criteria recommended
4. Included hauled waste, if appropriate?			X	
5. If included, conventional limits evaluated based on treatment plant design?		X		Proposed local limits based on MAHL calculations and are less stringent than existing LL.
6. Limits make sense based on influent/effluent/sludge monitoring evaluation?	X			